



INTERNATIONAL STANDARD

AMENDMENT 1

**Information technology - Generic cabling for customer premises -
Part 1: General requirements**

(<https://standards.iteh.ai>)
Document Preview

[ISO/IEC 11801-1:2017/Amd 1:2025](https://standards.iteh.ai/catalog/standards/iso/bf097e40-1381-4ac8-a6ca-cf4a891f09af/iso-iec-11801-1-2017-amd-1-2025)

<https://standards.iteh.ai/catalog/standards/iso/bf097e40-1381-4ac8-a6ca-cf4a891f09af/iso-iec-11801-1-2017-amd-1-2025>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2025 ISO/IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search -

webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

<https://standards.iteh.ai/catalog/standards/iso/bf097e40-1381-4ac8-a6ca-cf4a891f09af/iso-iec-11801-1-2017-amd-1-2025>

<https://standards.iteh.ai/catalog/standards/iso/bf097e40-1381-4ac8-a6ca-cf4a891f09af/iso-iec-11801-1-2017-amd-1-2025>

Warning! Make sure that you obtained this publication from an authorized distributor.

Information technology - Generic cabling for customer premises - Part 1: General requirements

AMENDMENT 1

FOREWORD

- 1) ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.
- 2) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO National bodies.
- 3) IEC and ISO documents have the form of recommendations for international use and are accepted by IEC and ISO National bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC and ISO documents is accurate, IEC and ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC and ISO National bodies undertake to apply IEC and ISO documents transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC and ISO document and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and ISO do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC and ISO marks of conformity. IEC and ISO are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this document.
- 7) No liability shall attach to IEC and ISO or their directors, employees, servants or agents including individual experts and members of its technical committees and IEC and ISO National bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this ISO/IEC document or any other IEC and ISO documents.
- 8) Attention is drawn to the Normative references cited in this document. Use of the referenced publications is indispensable for the correct application of this document.
- 9) IEC and ISO draw attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC and ISO take no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC and ISO had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch> and www.iso.org/patents. IEC and ISO shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to ISO/IEC 11801-1:2017 has been prepared by subcommittee 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

The text of this Amendment is based on the following documents:

Draft	Report on voting
JTC1-SC25/3285/CDV	JTC1-SC25/3337A/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Amendment is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1, and the ISO/IEC Directives, JTC 1 Supplement available at www.iec.ch/members_experts/refdocs and www.iso.org/directives.

INTRODUCTION TO THE AMENDMENT

This document specifies single pair component Categories T1-A, T1-B, and T1-C, as well as cabling channels and link Classes T1-A, T1-B, and T1-C to support single pair applications. Balanced single pair channels and links specified in this document are not a replacement for the generic 4-pair channels in ISO/IEC 11801-1:2017. They are an additional media type intended for use in intelligent building and industrial automation devices (e.g. in network sensors, actuators, and controllers). Because of the different types and locations of these devices, single pair cabling will have distinct structures and distribution architectures that are detailed in other parts of the ISO/IEC 11801 series.

This document also provides modifications and corrections to ISO/IEC 11801-1:2017.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/IEC 11801-1:2017/Amd 1:2025](https://standards.iteh.ai/catalog/standards/iso/bf097e40-1381-4ac8-a6ca-cf4a891f09af/iso-iec-11801-1-2017-amd-1-2025)

<https://standards.iteh.ai/catalog/standards/iso/bf097e40-1381-4ac8-a6ca-cf4a891f09af/iso-iec-11801-1-2017-amd-1-2025>

INTRODUCTION

Replace the existing Figure 1 with the following new figure:




Figure 1 – Relationships between the generic cabling documents produced by ISO/IEC JTC 1/SC 25

1 Scope

Replace existing bullet b) with the following:

- b) channel transmission, environmental and power delivery performance requirements;

2 Normative references

Add the following normative references at the end of the list:

IEC 60512-99-002, *Connectors for electrical and electronic equipment - Tests and measurements - Part 99-002: Endurance test schedules - Test 99b: Test schedule for unmating under electrical load*

IEC 61156-11, *Multicore and symmetrical pair/quad cables for digital communications - Part 11: Symmetrical single pair cables with transmission characteristics up to 1,25 GHz - Horizontal floor wiring - Sectional specification*

IEC 61156-12, *Multicore and symmetrical pair/quad cables for digital communications - Part 12: Symmetrical single pair cables with transmission characteristics up to 1,25 GHz - Work area wiring - Sectional specification*

IEC 61156-13, *Multicore and symmetrical pair/quad cables for digital communications - Part 13: Symmetrical single pair cables with transmission characteristics up to 20 MHz - Horizontal floor wiring - Sectional specification*

IEC 61156-14, *Multicore and symmetrical pair/quad cables for digital communications - Part 14: Symmetrical single pair cables with transmission characteristics up to 20 MHz - Work area wiring - Sectional specification*

IEC 61196-1-105, *Coaxial communication cables - Part 1-105: Electrical test methods - Test for withstand voltage of cable dielectric*

IEC 61935-4, *Specification for the testing of balanced and coaxial information technology cabling - Part 4: Installed balanced single-pair cabling as specified in ISO/IEC 11801-1 and related standards*¹

IEC 63171, *Connectors for electrical and electronic equipment - Shielded or unshielded free and fixed connectors for balanced single-pair data transmission with current-carrying capacity - General requirements and tests*

IEC 63171-1, *Connectors for electronic equipment - Part 1: Detail specification for two-way, shielded or unshielded, free and fixed connectors - Mechanical mating information, pin assignment and additional requirements for Type 1 copper LC style*

IEC 63171-6, *Connectors for electrical and electronic equipment - Part 6: Detail specification for 2-way and 4-way (data/power), shielded, free and fixed connectors for power and data transmission with frequencies up to 600 MHz*

ISO/IEC TS 29125, *Telecommunications cabling requirements for remote powering of terminal equipment*

¹ First edition under preparation. Stage at the time of publication: IEC CDV 61935-4:2025.

3.2 Abbreviations

Add the following new abbreviations at the end of the list:

PON	passive optical network
S-PoE	single pair Power over Ethernet
SP	single pair
SPE	single pair Ethernet

5.3.1 Cabling subsystem 1

Replace the last paragraph with the following paragraph:

Although terminal equipment cords and equipment cords are used to connect terminal and transmission equipment respectively to the cabling subsystem, they are not considered part of the cabling subsystem because they can be application specific.

6 Channel performance requirements

6.3.3.4.1 General

Delete the existing second paragraph.

6.3.3.6 Direct current loop resistance

Replace the existing Table 17 with the following new Table 17:

Table 17 – DC loop resistance for a channel

DC loop resistance ^a		
Class	Maximum DC loop resistance at 60 °C ^b	Informative DC loop resistance at 20 °C ^b
	Ω	Ω
A	560	472
B	170	143,3
C	40	33,7
D, E, E _A , F, F _A	25 ^c	21,1 ^e
BCT-B-L	4,0	3,4
BCT-B-M	6,9	5,8
I, II	6,4 ^d	5,4 ^f