

---

---

**Road vehicles — Inlet air cleaning  
equipment for internal combustion  
engines and compressors —**

Part 2:

**Fractional efficiency testing with coarse  
particles (5  $\mu\text{m}$  to 40  $\mu\text{m}$  optical diameter)**

*Véhicules routiers — Équipement d'épuration d'air d'entrée pour  
moteurs à combustion interne et compresseurs —*

*Partie 2: Contrôle d'efficacité fractionnelle avec grosses particules  
(diamètre optique de 5  $\mu\text{m}$  à 40  $\mu\text{m}$ )*

get full document from [standards.iteh.ai](https://standards.iteh.ai)



Reference number  
ISO/TS 19713-2:2010(E)

© ISO 2010

**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

# Sample Document

get full document from [standards.iteh.ai](https://standards.iteh.ai)



## **COPYRIGHT PROTECTED DOCUMENT**

© ISO 2010

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

**Contents**

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Test equipment, accuracy and validation</b> .....	<b>4</b>
<b>4.1 Measurement accuracy</b> .....	<b>4</b>
<b>4.2 Test stand configuration</b> .....	<b>5</b>
<b>4.3 Test conditions</b> .....	<b>12</b>
<b>4.4 Validation</b> .....	<b>13</b>
<b>4.5 Reference air cleaner assemblies/air filter elements</b> .....	<b>14</b>
<b>4.6 Routine operating procedure</b> .....	<b>14</b>
<b>5 Fractional efficiency test</b> .....	<b>14</b>
<b>5.1 General</b> .....	<b>14</b>
<b>5.2 Test procedure</b> .....	<b>15</b>
<b>Annex A (informative) Test report</b> .....	<b>17</b>
<b>Annex B (normative) Efficiency data reduction</b> .....	<b>19</b>
<b>Annex C (normative) Pressure loss data reduction</b> .....	<b>26</b>
<b>Annex D (informative) Determination of maximum efficiency aerosol concentration</b> .....	<b>27</b>
<b>Annex E (normative) Accuracy requirements, validation and routine operation</b> .....	<b>28</b>
<b>Annex F (informative) Particle diameters</b> .....	<b>31</b>
<b>Annex G (normative) Aerosol isokinetic sampling</b> .....	<b>33</b>
<b>Annex H (normative) Fractional efficiency</b> .....	<b>36</b>
<b>Bibliography</b> .....	<b>37</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

In other circumstances, particularly when there is an urgent market requirement for such documents, a technical committee may decide to publish other types of document:

- an ISO Publicly Available Specification (ISO/PAS) represents an agreement between technical experts in an ISO working group and is accepted for publication if it is approved by more than 50 % of the members of the parent committee casting a vote;
- an ISO Technical Specification (ISO/TS) represents an agreement between the members of a technical committee and is accepted for publication if it is approved by 2/3 of the members of the committee casting a vote.

An ISO/PAS or ISO/TS is reviewed after three years in order to decide whether it will be confirmed for a further three years, revised to become an International Standard, or withdrawn. If the ISO/PAS or ISO/TS is confirmed, it is reviewed again after a further three years, at which time it must either be transformed into an International Standard or be withdrawn.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO/TS 19713-2 was prepared by Technical Committee ISO/TC 22, *Road vehicles*, Subcommittee SC 7, *Injection equipment and filters for use on road vehicles*.

ISO/TS 19713 consists of the following parts, under the general title *Road vehicles — Inlet air cleaning equipment for internal combustion engines and compressors*:

- *Part 1: Fractional efficiency testing with fine particles (0,3 µm to 5 µm optical diameter)*
- *Part 2: Fractional efficiency testing with coarse particles (5 µm to 40 µm optical diameter)*

## Introduction

The engine air cleaner/filter fractional efficiency test methods described in this part of ISO/TS 19713 have been developed to cover traditional and new particulate air filters in order to remove airborne contaminants specifically to protect the engine.

Air cleaner fractional efficiency is one of the main air cleaner performance characteristics. This part of ISO/TS 19713 has been established to address the measurement of this parameter. The objective of the procedure is to maintain a uniform test method for evaluating fractional efficiency of air cleaners and air filters on specified laboratory test stands.

The data collected in accordance with this part of ISO/TS 19713 can be used to establish fractional efficiency characteristics for air cleaners and filters tested in this manner. The actual field operating conditions (including contaminants, humidity, temperature, mechanical vibration, flow pulsation, etc.) are difficult to duplicate. However, with the procedure and equipment set forth, comparison of air filter fractional efficiency can be made with a high degree of confidence.

# Sample Document

get full document from [standards.iteh.ai](https://standards.iteh.ai)

# Sample Document

get full document from [standards.iteh.ai](https://standards.iteh.ai)

# Road vehicles — Inlet air cleaning equipment for internal combustion engines and compressors —

## Part 2: Fractional efficiency testing with coarse particles (5 µm to 40 µm optical diameter)

### 1 Scope

This part of ISO/TS 19713 describes laboratory test methods to measure engine air cleaner and filter performance by fractional efficiency tests for particles from 5 µm to 40 µm, using ISO 12103-1 test dusts.

Performance includes, but is not limited to, airflow restriction or pressure loss, initial and incremental fractional efficiencies during dust loading.

ISO/TS 19713-1 describes fractional efficiency tests for particles from 0,3 µm to 5 µm optical diameter.

### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5011:2000, *Inlet air cleaning equipment for internal combustion engines and compressors — Performance testing*

ISO 12103-1, *Road vehicles — Test dust for filter evaluation — Part 1: Arizona test dust*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1

##### **air cleaner assembly**

assembly which includes the air cleaner housing and the air filter element

#### 3.1.1

##### **single-stage air cleaner**

air cleaner which does not incorporate a separate pre-cleaner

#### 3.1.2

##### **multistage air cleaner**

air cleaner consisting of two or more stages, the first usually being a pre-cleaner, followed by one or more filter elements

NOTE If two elements are used, the first is called the primary element and the second is called the secondary element.

**3.1.3**

**pre-cleaner**

device usually using inertial or centrifugal means to remove a portion of the test dust before reaching the filter element

**3.2**

**air filter element**

actual filter supported and sealed within the air cleaner assembly

**3.3**

**test airflow rate**

measure of the volume of air passing through the test duct per unit time

NOTE The test airflow rate is expressed in cubic metres per second.

**3.4**

**pressure loss**

permanent pressure reduction due to a decrease in the flow energy (velocity head) caused by the filter (Pa at standard conditions of 20 °C and 101,3 kPa)

**3.5**

**fractional efficiency**

$E_{f,i}$

ability of the air filter to remove particles of a specified size expressed as a percentage for particle size  $i$

$$E_{f,i} = \frac{C_{1,i} - C_{2,i}}{C_{1,i}} \times 100 \quad (1)$$

where

$C_{1,i}$  is the number of particles per unit volume of specified size,  $i$ , upstream;

$C_{2,i}$  is the number of particles per unit volume of specified size,  $i$ , downstream

NOTE Fractional efficiency is expressed in percent.

**3.6**

**fractional efficiency before dust loading**

efficiency before the collected particles have any measurable effect on the efficiency of the filter under test

NOTE The collected particles can affect the measured filter efficiency before enough aerosol is collected to have any measurable effect on the filter pressure loss.

**3.7**

**incremental fractional efficiency**

efficiency, determined at the specified flow rate as a function of particle size at 10 %, 25 %, 50 % and 100 % of filter life, which is determined by pressure loss across the filter as the filter is loaded with ISO 12103-1 test dust

NOTE 1 The values of filter pressure loss,  $\Delta P_p$ , at which the incremental fractional efficiencies are measured can be calculated from

$$\Delta P_i = \Delta P_o + \Delta L_i(\Delta P_d - \Delta P_o) \quad (2)$$

where

$\Delta P_o$  is the initial pressure loss;

$\Delta L_i$  is the fraction of filter life;

$\Delta P_d$  is the specified terminal pressure loss.

NOTE 2 If necessary, the requester and the tester can agree upon different criteria for incremental fractional efficiency.

### 3.8 fractional penetration

$P_{f,i}$

ratio of the concentration of particles of specified size exiting the filter to the concentration of particles of specified size entering the filter expressed in a percentage for particle size  $i$

$$P_{f,i} = 100 - E_{f,i} \quad (3)$$

NOTE Fractional penetration is expressed in percent.

### 3.9 test dust loading

mass of test dust collected by the air cleaner assembly or air filter element at a specified flow rate expressed in grams

### 3.10 particle measurement device aerosol spectrometer

instrument for sizing, or counting, or sizing and counting, aerosol particles

NOTE Recommended particle counters are optical particle counters (OPC) or other counters demonstrating good correlation in measuring particle sizes, e.g. aerodynamic particle counters (APC).

### 3.11 test aerosol

particles suspended in air, used for filter efficiency evaluation or dust loading

#### 3.11.1 fractional efficiency test aerosol

aerosol used to measure the efficiency of the test filter, the concentration of which is low enough to prevent coincidence-related errors in the particle counters, and does not change the filter efficiency due to loading

NOTE The aerosol charge is reduced so that it approximates a Boltzman equilibrium charge distribution. The requirements for the efficiency challenge aerosol are given in 4.2.10 and 4.2.11.

#### 3.11.2 loading test aerosol

aerosol used to load the filter, the concentration of which is high enough to allow loading of the filter in a reasonable amount of time

NOTE The requirements for the loading test aerosol are given in 4.2.13.2.

### 3.12 correlation ratio

$R$

ratio of the number of particles observed at the downstream sampling location to the number of particles at the upstream sampling location when no filter is installed in the test system

NOTE 1 This number can be greater or less than 1.

NOTE 2 The method of calculating the correlation ratio is given in Annex B.

**3.13**  
**log mean diameter**

$D_{l,i}$   
weighted mean diameter calculated by

$$D_{l,i} = (D_i \times D_{i+1})^{1/2} \quad (4)$$

where

$D_i$  is the lower threshold of particle size range;

$D_{i+1}$  is the upper threshold of particle size range

**3.14**  
**geometric (volume equivalent) diameter**

$D_{g,i}$   
diameter of a sphere with the same volume as the particle being measured

NOTE For a spherical particle, it is the diameter of the sphere.

**3.15**  
**optical (equivalent) diameter**

$D_{o,i}$   
diameter of a particle of the type used to calibrate an optical sizing instrument that scatters the same amount of light as the particle being measured

NOTE Optical diameter depends on the instrument, the type of particle used to calibrate the instrument (usually polystyrene latex spheres), the optical properties of the particle being measured, and the size of the particle.

**3.16**  
**aerodynamic (equivalent) diameter**

$D_{ae}$   
diameter of a sphere of density 1 g/cm<sup>3</sup> with the same terminal velocity as the particle being measured, due to gravitational force in calm air

NOTE 1 The aerodynamic diameter will be used to report results to avoid different diameter measures due to different sizing and counting techniques.

NOTE 2 Annex F provides additional information about aerodynamic diameter.

**3.17**  
**high efficiency particulate air**  
**HEPA**

filter having 99,95 % efficiency at most penetrating particle size (class H13 in accordance with EN 1822), or 99,97 % (or higher) fractional efficiency at 0,3 µm using DOP aerosol as defined by IEST RP-CC001 recommended practice

**3.18**  
**neutralization**

aerosol whose charge distribution is reduced until it provides a Boltzman equilibrium charge distribution

## 4 Test equipment, accuracy and validation

### 4.1 Measurement accuracy

Accuracy requirements are given in Table E.1.

## 4.2 Test stand configuration

### 4.2.1 General

Complete vehicle manufacturer air cleaner assemblies or individual air filter elements may be tested. The test stand shall consist of the following major components and shall be arranged as shown in Figure 2.

NOTE 1 Results can vary depending on configuration.

NOTE 2 Air cleaner assembly orientation will affect performance. It is advisable that air cleaner assemblies be oriented and tested as installed in the vehicle.

Figure 2 shows a set-up to measure the performance of an air cleaner assembly.

Figure 3 shows a recommended air cleaner housing to measure the performance of a panel-type air filter element.

Figure 4 shows a recommended air cleaner housing to measure the performance of a cylindrical-type air filter element.

### 4.2.2 Unit under test

#### 4.2.2.1 General

The unit under test may be an air cleaner housing with filter element or elements or it may be a housing designed to hold a filter element with appropriate inlet and outlets. The unit under test may be or may include a pre-cleaner. The scope of this test procedure does not include the testing of air cleaner systems without tubular inlet and outlet connections. However, designs such as perforated or louvered inlet systems could be tested with the unit under test inside a plenum that would include a tubular inlet. Non-tubular air cleaner systems outside the scope of this test procedure may still be evaluated as agreed upon between the tester and customer.

#### 4.2.2.2 Air cleaner assembly

Air cleaner assemblies shall be evaluated using the set-up shown in Figure 2.

#### 4.2.2.3 Evaluating panel air filter elements

In general, panel-type air filter elements may be tested using the recommended housing shown in Figure 3.

#### 4.2.2.4 Evaluating cylindrical/round air filter elements

Figure 4 shows a recommended housing to test cylindrical-type air filter elements. This housing design is similar to the one recommended in ISO 5011.

### 4.2.3 Ducting

Upstream and downstream cylindrical ducting shall be made of conductive material and all components shall be commonly grounded from the aerosol inlet section to the downstream sampling section.

### 4.2.4 Airflow conditioning

Inlet air shall be conditioned in accordance with the requirements of ISO 5011, i.e.  $(23 \pm 5)$  °C and  $(55 \pm 15)$  % relative humidity (RH). The inlet air shall be filtered with a HEPA filter if the background particle concentration exceeds that defined in Annex E.

**4.2.5 Test configurations**

The upstream and downstream ducting can be constructed vertically (recommended), horizontally, or a combination based on space constraints. The example in this procedure shows a vertical configuration to test both air cleaners and panel-type air filters. Preferably, the particle samplers should be located vertically in each test section, which reduces the probability of particle loss and enables sampling of large particle sizes of interest. The underlying test system design will reduce particle losses and meet the requirements of Tables E.1 and E.2.

**4.2.6 Airflow ducting**

The test system should be capable of handling user-specified flow rates. Further, the test system will maintain the required flow rates with air cleaner assembly pressure loss up to 10 kPa. Primary duct sizing shall conform to the “nominal” duct diameter and Reynolds numbers in Table 1. Higher and lower flow rates may use duct sizes scaled appropriately.

**Table 1 — Duct diameter versus flow range**

Nominal duct diameter mm	Area m <sup>2</sup>	Velocity m/s	Flow range low m <sup>3</sup> /h	Flow range high m <sup>3</sup> /h	Reynolds number	
					at low flow	at high flow
50	0,002 02	11,6	85	425	40 407	202 034
100	0,008 10	5,8	170	850	40 407	202 034
150	0,018 20	5,2	340	1 700	53 876	269 378
200	0,032 40	5,8	680	3 400	80 813	404 067

NOTE A 10 µm particle with a specific gravity of 2 settles at about  $6 \times 10^{-3}$  m/s in still air. At the minimum velocity of approximately 5,1 m/s, this would result in a 10 mm drop in that 10 µm particle over a 3 m run.

**4.2.7 Inlet filtration**

Test inlet airflow shall be filtered with a HEPA filter to remove the majority of ambient aerosol, if required, in accordance with Annex E.

**4.2.8 Flow uniformity**

The test system shall be designed to provide uniform and steady airflow to the air cleaner assembly or to the air filter element under test, as stated in the test set-up.

NOTE Uniform airflow is required in sections where isokinetic samplers are located when evaluating air cleaner assemblies. Proper flow distribution will facilitate a representative aerosol sample being drawn by the isokinetic samplers. See 4.2.10.4 for flow uniformity measurements.

**4.2.9 Leakage**

It is important to minimize leakage into the test system to obtain valid data. Depending on where the leakage occurs, it can cause major errors in particle counting.

As a minimum, all connections and joints should be checked for visual leakage using soap bubbles. Any known soap solution can be used for the test. Preferably, the soap solution (foam) will be applied using a brush at all connections and joints. Leaks are especially important on the clean side of the air cleaner.