
**Toplotna črpalka s plinsko gnanim motorjem z notranjim zgorevanjem - 5. del:
Izračun sezonske zmogljivosti za ogrevanje in hlajenje**

Gas-fired endothermic engine driven heat pumps - Part 5: Calculation of seasonal performances in heating and cooling mode

Gasbefeuerte endothermische Motor-Wärmepumpen - Teil 5: Berechnung der saisonalen Effizienzkennzahlen im Heiz- und Kühlmodus

Pompes à chaleur à moteur endothermique alimenté au gaz - Partie 5 : Calcul des performances saisonnières en modes chauffage et refroidissement

Ta slovenski standard je istoveten z: prEN 16905-5

ICS:

27.080 Toplotne črpalke Heat pumps

oSIST prEN 16905-5:2026 **en,fr,de**

Sample Document

get full document from standards.iteh.ai

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 16905-5

April 2026

ICS 27.080

Will supersede EN 16905-5:2022

English Version

Gas-fired endothermic engine driven heat pumps - Part 5: Calculation of seasonal performances in heating and cooling mode

Pompes à chaleur à moteur endothermique alimenté
au gaz - Partie 5 : Calcul des performances saisonnières
en modes chauffage et refroidissement

Gasbefeuerte endothermische Motor-Wärmepumpen -
Teil 5: Berechnung der saisonalen Effizienzkennzahlen
im Heiz- und Kühlmodus

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 299.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2026 CEN All rights of exploitation in any form and by any means reserved
worldwide for CEN national Members.

Ref. No. prEN 16905-5:2026 E

Contents	Page
European foreword.....	5
Introduction	6
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions	7
4 Part load conditions for space cooling	8
4.1 General.....	8
4.2 Air-to-air units	8
4.3 Water-to-air and brine-to-air units.....	9
4.4 Air-to-water and air-to-brine units	9
4.5 Water-to-water and brine-to-water units.....	10
5 Part load conditions for space heating.....	12
5.1 General.....	12
5.2 Air-to-air units	12
5.3 Water(brine)-to-air units.....	13
5.4 Air-to-water(brine) units.....	14
5.4.1 General.....	14
5.4.2 Low temperature application.....	14
5.4.3 Intermediate temperature application.....	15
5.4.4 Medium temperature application.....	16
5.5 DX-to-water(brine), water-to-water(brine), brine-to-water(brine) units	16
5.5.1 General.....	16
5.5.2 Low temperature application	17
5.5.3 Intermediate temperature application.....	18
5.5.4 Medium temperature application.....	19
6 Calculation methods for reference $SPER_c$.....	19
6.1 General.....	19
6.2 General formula for calculation of GUE_c and AEF_c	20
6.3 General formula for calculation of $EHRE_c$ and $AEHRF_c$	20
6.4 General formula for calculation of reference $SGUE_c$	20
6.5 Calculation of reference $SEHRE_c$	21
6.6 Calculation of reference $SGUE_{TC}$	22
6.7 Calculation of reference $SAEF_c$	22
6.8 Calculation of reference annual cooling demand ($Q_{ref,c}$).....	23
6.9 Calculation of reference $SAEF_{CON}$	23
6.10 Calculation of reference $SAEHRF_c$	24
6.11 Calculation of reference total $SAEF_{TC}$	24
6.12 Procedures for the determination of GUE_{cPL} / AEF_{cPL} values.....	24
6.13 Procedures for the determination of $EHRE_{cPL}$ / $AEHRF_{cPL}$ values	24
6.14 Calculation of reference $SPER_c$	25
6.15 Calculation of the annual primary energy consumption cooling Q_{CP}	25
6.16 Calculation of the seasonal space cooling efficiency $\eta_{s,c}$	25
7 Calculation methods for reference $SPER_h$.....	26
7.1 General.....	26

7.2	General formula for calculation of GUE_h and AEF_h	26
7.3	General formula for calculation of $EHRE_h$	26
7.4	General formula for calculation of reference $SGUE_h$	27
7.5	Calculation of reference $SEHRE_h$	29
7.6	Calculation of reference $SGUE_{Th}$	30
7.7	Calculation of reference $SAEF_h$	30
7.8	Calculation of reference annual heating demand ($Q_{ref,h}$).....	30
7.9	Calculation of reference $SAEF_{hON}$	31
7.10	Calculation of reference $SAEHRF_h$	31
7.11	Calculation of reference total $SAEF_{Th}$	32
7.12	Procedures for the determination of GUE_{hPL} / AEF_{hPL} values.....	32
7.13	Procedures for the determination of $EHRE_{hPL}$ / $AEHRF_{hPL}$ values.....	32
7.14	Calculation of reference $SPER_h$	32
7.15	Calculation of the annual primary energy consumption heating Q_{HP}	33
7.16	Calculation of the seasonal space heating efficiency η_{sh}	33
8	Technical documentation.....	33
Annex A	(normative) Determination of reference annual cooling/heating demands and determination of hours for active mode, thermostat off, standby, off mode and crankcase heater mode for reference $SAEF_c$ and $SAEF_h$ calculation.....	35
A.1	Air-to-air, water-to-air and brine-to-air units.....	35
A.1.1	Hours for active mode, thermostat-off and standby.....	35
A.1.2	Hours for crankcase heater mode.....	36
A.2	Air-to-water, air-to-brine, water-to-water, brine-to-water, DX -to-water and DX-to brine units.....	36
A.2.1	Hours for active mode, thermostat-off and standby.....	36
A.2.2	Hours for crankcase heater mode.....	37
Annex B	(informative) Calculation example for reference $SGUE_c$, $SAEF_c$, $SEHRE_c$, $SAEHRF_c$, $SGUE_{Tc}$, $SAEF_{Tc}$ and $SPER_c$	38
Annex C	(informative) Calculation example for reference $SGUE_h$, $SAEF_h$, $SEHRE_h$, $SAEHRF_h$, $SGUE_{Th}$, $SAEF_{Th}$ and $SPER_h$	41
Annex D	(informative) Template for technical documentation.....	44
Annex E	(normative) Rating of outdoor units of multi-split air conditioners and heat pumps.....	49
E.1	General.....	49
E.2	Terms and definitions.....	49
E.3	Rating of outdoor units.....	50
E.3.1	General.....	50
E.3.2	Test procedure.....	51
E.4	Calculation of the $SPER_c$ based on the $PER_{c outdoor}$	51
E.5	Calculation of the $SPER_h$ based on the $SPER_{h outdoor}$	51
Annex F	(normative) Calculation procedure for determination of GUE_{TPL} , AEF_{TPL} and test procedure for units with fixed or variable capacity and Cd values.....	52
F.1	Calculation procedure for determination of GUE values at part load conditions (cooling A to D heating A to G) (GUE_{TPL}).....	52

prEN 16905-5:2026 (E)

F.1.1	General	52
F.1.2	For air-to-air, brine-to-air and water-to-air units	52
F.1.3	For air-to-water, water-to-water and brine-to-water units	53
F.2	Calculation procedure for determination of AEF values at part load conditions (cooling A to D heating A to G) (AEFPL)	54
F.2.1	General	54
F.2.2	For air-to-air, brine-to-air and water-to-air units	54
F.2.3	For air-to-water, water-to-water and brine-to-water units	55
F.3	Test procedures for units with fixed capacity	55
F.3.1	General	55
F.3.2	Air-to-air and water-to-air units - Determination of the degradation coefficient Cd	57
F.3.3	Air-to-water(brine) units and water(brine)-to-water(brine) and DX-to-water(brine) units - Determination of the degradation coefficient Cd	58
F.4	Test procedure for staged and variable capacity units	59
F.4.1	General	59
F.4.2	Settings for the required capacity ratio	59
F.4.3	Compensation method	59
Annex ZA	(informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 813/2013 OJ L 239/83 (6.9.2013) aimed to be covered	60
Annex ZB	(informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 2016/2281 OJ L 346/1 (30-11-2016) aimed to be covered	62
Annex ZC	(informative) Relationship between this European Standard and the energy labelling requirements of Commission Regulation (EU) No 811/2013 OJ L 239/1 (6.9.2013) aimed to be covered	64
Bibliography	65

European foreword

This document (prEN 16905-5:2026) has been prepared by Technical Committee CEN/TC 299 “Gas-fired sorption appliances, indirect fired sorption appliances, gas-fired endothermic engine heat pumps and domestic gas-fired washing and drying appliances”, the secretariat of which is held by UNI.

This document is currently submitted to the CEN Enquiry.

This document supersedes EN 16905-5:2022.

prEN 16905-5:2026 includes the following significant technical changes with respect to EN 16905-5:2022:

Addition of Annex ZA, ZB and ZC in order to achieve harmonization to Commission Regulation (EU) No 813/2013, Commission Regulation (EU) 2016/2281 and Commission Delegated Regulation (EU) No 811/2013.

This document has been prepared under Standardization Requests addressed to CEN by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

For the relationship with EU Legislation, see informative Annex ZA, Annex ZB and Annex ZC which are integral parts of this document.

EN 16905 comprises the following parts under the general title *Gas-fired endothermic engine driven heat pumps*:

- *Part 1: Terms and definitions;*
- *Part 2: Safety;*
- *Part 3: Tests conditions;*
- *Part 4: Tests methods;*
- *Part 5: Calculation of seasonal performances in heating and cooling mode.*

prEN 16905-5:2026 (E)**Introduction**

This document specifies the calculation of seasonal performances in heating and cooling mode of air conditioners and heat pumps using either air, water or brine as heat transfer media, with gas-fired endothermic engine driven compressors when used for space heating, cooling and refrigeration, hereafter referred to as “GEHP appliance”.

Single split and multisplit systems are covered by this document.

The GEHP appliances can have one or more primary or secondary functions.

The GEHP appliances having their condenser cooled by air and by the evaporation of external additional water are not covered by this document.

prEN 16905-5:2026 has been prepared to address the essential requirements of the European Regulation (EU) 2016/426 relating to appliances burning gaseous fuels and repealing Directive 2009/142/EC (see EN 16905-4:2026, Annex ZA).

EN 16905-1:2023, EN 16905-3:2024, EN 16905-4:2026 and prEN 16905-5:2026 are linked to the Energy Related Products Directive (2009/125/EC) in terms of tests conditions, tests methods and seasonal performances calculation methods under Mandate M/535; (see EN 16905-3:2024, Annex ZA, EN 16905-4:2026, Annex ZA, prEN 16905-5:2026, Annex ZA, Annex ZB and Annex ZC).

These documents will be reviewed whenever new mandates could apply.

Sample Document

get full document from standards.iteh.ai

1 Scope

This part of EN 16905 specifies the calculation of the seasonal performance factor for gas-fired endothermic engine driven heat pumps for heating and/or cooling mode including the engine heat recovery, to be used outdoors.

This document only applies to appliances with a maximum heat input (based on net calorific value) not exceeding 70 kW at standard rating conditions.

This document only applies to appliances under categories I_{2H} , I_{2E} , I_{2Er} , I_{2R} , $I_{2E(S)B}$, I_{2L} , I_{2LL} , I_{2ELL} , $I_{2E(R)B}$, I_{2ESi} , $I_{2E(R)}$, I_{3P} , I_{3B} , $I_{3B/P}$, II_{2H3+} , II_{2Er3+} , $II_{2H3B/P}$, $II_{2L3B/P}$, $II_{2E3B/P}$, $II_{2ELL3B/P}$, II_{2L3P} , II_{2H3P} , II_{2E3P} and II_{2Er3P} according to EN 437.

This document only applies to appliances having:

- a) gas fired endothermic engines under the control of fully automatic control systems;
- b) closed system refrigerant circuits in which the refrigerant does not come into direct contact with the fluid to be cooled or heated;
- c) where the temperature of the heat transfer fluid of the heating system (heating water circuit) does not exceed 105 °C during normal operation;
- d) where the maximum operating pressure in the:
 - 1) heating water circuit (if installed) does not exceed 6 bar,
 - 2) domestic hot water circuit (if installed) does not exceed 10 bar.

This document applies to GEHP appliances only when used for space heating or space cooling or for refrigeration, with or without heat recovery.

This document is applicable to GEHP appliances that are intended to be type tested. Requirements for GEHP appliances that are not type tested would need to be subject to further consideration.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 16905-1:2023, *Gas-fired endothermic engine driven heat pumps — Part 1: Terms and definitions*

EN 16905-4:2026, *Gas-fired endothermic engine driven heat pumps — Part 4: Test methods*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 16905-1:2023 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

4 Part load conditions for space cooling

4.1 General

For the purpose of calculation of application $SGUE_c$, $SAEF_c$, $SEHRE_c$, $SAEHRF_c$, $SGUE_{Tc}$, $SAEF_{Tc}$ and reference $SGUE_c$, $SAEF_c$, $SEHRE_c$, $SAEHRF_c$, $SGUE_{Tc}$, $SAEF_{Tc}$ as explained in Clauses 6 and 7, the part load ratios mentioned below shall be based on the part load ratio formulas with at least two decimal digits. For the purpose of $SGUE_c$, $SAEF_c$, $SEHRE_c$, $SAEHRF_c$, $SGUE_{Tc}$, $SAEF_{Tc}$ the different conditions shall be defined by a reference design temperature $T_{designc}$ equal to 35 °C.

The calculation of $SGUE_c$, $SAEF_c$, $SEHRE_c$, $SAEHRF_c$, $SGUE_{Tc}$, $SAEF_{Tc}$ and reference $SGUE_c$, $SAEF_c$, $SEHRE_c$, $SAEHRF_c$, $SGUE_{Tc}$, $SAEF_{Tc}$ is determined via linear interpolation of the respective part load values at the reference part load conditions mentioned below (A, B, C, D).

4.2 Air-to-air units

For outdoor air-to-recycled air units, the part load conditions for determining the declared capacity (DC) and the declared GUE_c , AEF_c , $EHRE_c$, $AEHRF_c$, GUE_{Tc} , AEF_{Tc} shall be given in Table 1.

Table 1 — Part load conditions for outdoor air-to- recycled air units

	Formula	Part load ratio	Outdoor heat exchanger	Indoor heat exchanger
			Air dry bulb temperature	Air dry (wet) bulb temperatures
		%	°C	°C
A	$(35-16)/(T_{designc}-16)$	100,00	35	27(19)
B	$(30-16)/(T_{designc}-16)$	73,68	30	27(19)
C	$(25-16)/(T_{designc}-16)$	47,37	25	27(19)
D	$(20-16)/(T_{designc}-16)$	21,05	20	27(19)

4.3 Water-to-air and brine-to-air units

For water-to-air and brine-to-air units, the part load conditions for determining the declared capacity (DC) and the declared GUE_c , AEF_c , $EHRE_c$, $AEHRF_c$, GUE_{Tc} , AEF_{Tc} shall be given in Table 2.

Table 2 — Part load conditions for water-to-air and brine-to-air units

	Formula	Part load ratio %	Outdoor heat exchanger			Indoor heat exchanger
			Cooling tower or water(brine) loop application Inlet/outlet water(brine) temperatures °C	Ground coupled application Inlet/outlet water(brine) temperatures °C	Dry cooler application Inlet/outlet water temperatures °C	Air dry (wet) bulb temperature °C
A	$(35-16)/(T_{designc}-16)$	100,00	30/35	10/15	50/55	27(19)
B	$(30-16)/(T_{designc}-16)$	73,68	26/ ^a	10/ ^a	45/ ^a	27(19)
C	$(25-16)/(T_{designc}-16)$	47,37	22/ ^a	10/ ^a	40/ ^a	27(19)
D	$(20-16)/(T_{designc}-16)$	21,05	18/ ^a	10/ ^a	35/ ^a	27(19)

If a cooling tower and a water-to-air unit are sold as a matched assembly, they shall be tested as an air-to-air unit.

^a With the flow rate as determined during “A” test for units with a fixed flow rate or a fixed water temperature difference of 5 °K for units with a variable flow rate. If for any of the test conditions the resulting flow rate is below the minimum flow rate then this minimum flow rate is used as a fixed flow rate with the inlet temperature for this test condition.

4.4 Air-to-water and air-to-brine units

For each application, units either allowing or not allowing a variation of the outlet water/brine temperature with the outdoor temperature are considered. The part load conditions for determining the declared capacity (DC) and the declared GUE_c , AEF_c , $EHRE_c$, $AEHRF_c$, GUE_{Tc} , AEF_{Tc} shall be given in Table 3.

The variable outlet temperature ($T_{outlet,average}$) shall only be applied when the control provides a regulation of outlet water temperature that considers the outdoor temperature.

For the determination of water (brine) temperature for fixed capacity units with variable outlet temperature refer to EN 16905-4:2026.

For units with variable outlet that have to cycle on/off to reach the required part load ratio, the inlet and outlet temperatures of the indoor heat exchanger shall be determined according to EN 16905-4:2026, Annex H.

Table 3 — Part load conditions of air-to-water and air-to-brine units

Formula	Part load ratio	Outdoor heat exchanger	Indoor heat exchanger			
			Outdoor air dry bulb temperature	Fan coil application Inlet/outlet water(brine) temperatures		Cooling floor application Inlet/outlet water(brine) temperatures
				Fixed outlet	Variable outlet ^b	
	%	°C	°C	°C	°C	
A	$(35-16)/(T_{designc}-16)$	100,00	35	12/7	12/7	23/18
B	$(30-16)/(T_{designc}-16)$	73,68	30	^a /7	^a /8,5	^a /18
C	$(25-16)/(T_{designc}-16)$	47,37	25	^a /7	^a /10	^a /18
D	$(20-16)/(T_{designc}-16)$	21,05	20	^a /7	^a /11,5	^a /18

^a With the flow rate as determined during “A” test for units with a fixed flow rate or with a fixed water temperature difference 5 K for units with a variable flow rate. If for any of the test conditions the resulting flow rate is below the minimum flow rate then this minimum flow rate is used as a fixed flow rate with the outlet temperature for this test condition.

^b If the variable outlet temperature is above the maximum of the operating range of the unit, this maximum should be considered.

4.5 Water-to-water and brine-to-water units

For each application, units either allowing or not allowing a variation of the outlet water/brine temperature with the outdoor temperature are considered. The part load conditions for determining the declared capacity (DC) and the declared GUE_c , AEF_c , $EHRE_c$, $AEHRF_c$, GUE_{Tc} , AEF_{Tc} shall be given in Table 4.

The variable outlet temperature ($T_{outlet,average}$) shall only be applied when the control provides a regulation of outlet water temperature that considers the outdoor temperature.

For the determination of water (brine) temperature for fixed capacity units with variable outlet temperature refer to EN 16905-4:2026.

For units with variable outlet that have to cycle on/off to reach the required part load ratio, the inlet and outlet temperatures of the indoor heat exchanger shall be determined according to EN 16905-4:2026, Annex H.

prEN 16905-5:2026 (E)

Table 4 — Part load conditions of water-to-water, water-to-brine, brine-to-water, brine-to-brine and DX-to-water units

Formula	Part load ratio %	Outdoor heat exchanger				Indoor heat exchanger			
		Cooling tower or water(brine) loop application Inlet/outlet water(brine) temperatures °C	Ground coupled application Inlet/outlet water(brine) temperatures °C	Dry cooler application Inlet/outlet water(brine) temperatures °C	DX Bath temperature	Fan coil application Inlet/outlet water temperatures		Cooling floor application Inlet/outlet water temperatures °C	
						Fixed outlet °C	Variable outlet ^b °C		
A	$(35-16) / (T_{designc}-16)$	100,00	30/35	10/15	50/55	30	12/7	12/7	23/18
B	$(30-16) / (T_{designc}-16)$	73,68	26/ ^a	10/ ^a	45/ ^a	30	^a /7	^a /8,5	^a /18
C	$(25-16) / (T_{designc}-16)$	47,37	22/ ^a	10/ ^a	40/ ^a	30	^a /7	^a /10	^a /18
D	$(20-16) / (T_{designc}-16)$	21,05	18/ ^a	10/ ^a	35/ ^a	30	^a /7	^a /11,5	^a /18

If a cooling tower and water-to-water unit are sold as a matched assembly, they shall be tested as an air-to-water unit.

^a With the flow rate as determined during “A” test for units with a fixed flow rate or with a fixed water temperature difference of 5 K for units with a variable flow rate. If for any of the test conditions the resulting flow rate is below the minimum flow rate then this minimum flow rate is used as a fixed flow rate with the outlet temperature for this test condition.

^b If the variable outlet temperature is above the maximum of the operating range of the unit, this maximum should be considered.

5 Part load conditions for space heating

5.1 General

For the purpose of calculation of $SGUE_h$, $SAEF_h$, $SEHRE_h$, $SAEHRF_h$, $SGUE_{Th}$, $SAEF_{Th}$, and reference $SGUE_h$, $SAEF_h$, $SEHRE_h$, $SAEHRF_h$, $SGUE_{Th}$, $SAEF_{Th}$, as explained in Clauses 6 and 7, the part load ratios mentioned below shall be based on the part load ratio formulas with at least two decimal digits.

The calculation of $SGUE_h$, $SAEF_h$, $SEHRE_h$, $SAEHRF_h$, $SGUE_{Th}$, $SAEF_{Th}$ and reference $SGUE_h$, $SAEF_h$, $SEHRE_h$, $SAEHRF_h$, $SGUE_{Th}$, $SAEF_{Th}$ is determined via linear interpolation of the respective part load values at the reference part load conditions mentioned below (A, B, C, D). For the purpose of reference $SGUE_h$, $SAEF_h$, $SEHRE_h$, $SAEHRF_h$, $SGUE_{Th}$, $SAEF_{Th}$ there are three reference conditions: average(A), warmer (W) and colder (C).

The relevant $T_{designh}$ values are defined as follows:

- | | |
|-------------------|---|
| — Average climate | dry bulb temperature conditions at -10 °C outdoor temperature and 20 °C indoor temperature; |
| — Colder climate | dry bulb temperature conditions at -22 °C outdoor temperature and 20 °C indoor temperature |
| — Warmer climate | dry bulb temperature conditions at $+2\text{ °C}$ outdoor temperature and 20 °C indoor temperature |

For outdoor air dry bulb temperatures higher or equal to -10 °C the wet bulb temperature equals the dry bulb temperature minus 1 K. For dry bulb temperatures below -10 °C , the wet bulb temperature is not defined.

For heat pumps, the relevant T_{biv} is defined as follows:

- for the average heating season, the dry bulb temperature is $+2\text{ °C}$ or lower;
- for the colder heating season, the dry bulb temperature is -7 °C or lower;
- for the warmer heating season, the dry bulb temperature is $+7\text{ °C}$ or lower.

For heat pumps, the relevant TOL is defined as follows:

- for the average heating season, the dry bulb temperature is -7 °C or lower;
- for the colder heating season, the dry bulb temperature is -15 °C or lower;
- for the warmer heating season, the dry bulb temperature is $+2\text{ °C}$ or lower.

If the declared TOL is lower than the $T_{designh}$ of the considered climate, then the outdoor dry bulb temperature is equal to $T_{designh}$ for the part load condition E in Table 5, Tables 7 to 10.

In case of colder climate and if TOL is below -20 °C , an additional part load condition G at -15 °C shall apply for air-to-air and air-to-water heat pumps.

5.2 Air-to-air units

The part load conditions for determining the reference $SGUE_h$ (Formula (16)), $SAEF_h$ (Formula (20)), $SEHRE_h$ (Formula (18)), $SAEHRF_h$ (Formula (23)), $SGUE_{Th}$ (Formula (19)), $SAEF_{Th}$ (Formula (24)), shall be given in Table 5.

Table 5 — Part load conditions for air-to-recycled air units for the reference heating seasons

Condition	Part load ratio in %				Outdoor heat exchanger	Indoor heat exchanger
	Formula	Average	Warmer	Colder	Air dry (wet) bulb temperature °C	Air dry bulb temperature °C
A	$(-7-16)/(T_{\text{designh}}-16)$	88,46	n/a	60,53	-7(-8)	20
B	$(+2-16)/(T_{\text{designh}}-16)$	53,85	100,00	36,84	2(1)	20
C	$(+7-16)/(T_{\text{designh}}-16)$	34,62	64,29	23,68	7(6)	20
D	$(+12-16)/(T_{\text{designh}}-16)$	15,38	28,57	10,53	12(11)	20
E	$(TOL-16)/(T_{\text{designh}}-16)$				TOL	20
F	$(T_{\text{biv}}-16)/(T_{\text{designh}}-16)$				T_{biv}	20
G	$(-15-16)/(T_{\text{designh}}-16)$	n/a	n/a	81,58	-15	20

5.3 Water(brine)-to-air units

The part load conditions for determining the reference $SGUE_h$ (Formula (16)), $SAEF_h$ (Formula (20)), $SEHRE_h$ (Formula (18)), $SAEHRF_h$ (Formula (23)), $SGUE_{Th}$ (Formula (19)), $SAEF_{Th}$ (Formula (24)), shall be given in Table 6.

Table 6 — Part load conditions for water(brine)-to-air for the reference heating seasons

Condition	Part load ratio in %				Outdoor heat exchanger inlet/outlet temperature			Indoor heat exchanger
	Formula	Average	Warmer	Colder	Water	Brine	Water loop	Dry bulb
					°C	°C	°C	
A	$(-7-16)/(T_{\text{designh}}-16)$	88,46	n/a	60,53	10/ ^a	0/ ^a	20/ ^a	20
B	$(+2-16)/(T_{\text{designh}}-16)$	53,85	100,00	36,84	10/ ^a	0/ ^a	20/ ^a	20
C	$(+7-16)/(T_{\text{designh}}-16)$	34,62	64,29	23,68	10/ ^a	0/ ^a	20/ ^a	20
D	$(+12-16)/(T_{\text{designh}}-16)$	15,38	28,57	10,53	10/ ^a	0/ ^a	20/ ^a	20
E	$(T_{\text{designh}}-16)/(T_{\text{designh}}-16)$	100,00	100,00	100,00	10/ ^a	0/ ^a	20/ ^a	20
F	$(T_{\text{biv}}-16)/(T_{\text{designh}}-16)$				10/ ^a	0/ ^a	20/ ^a	20

^a With the flow rate as determined at the standard rating conditions for units with a fixed flow rate or with a fixed water temperature difference of 3 K for units with a variable flow rate. If for any of the test conditions the resulting flow rate is below the minimum flow rate then this minimum flow rate is used as a fixed flow rate with the inlet temperature for this test condition.