

SLOVENSKI STANDARD
oSIST prEN IEC 60071-1:2026
01-marec-2026

Koordinacija izolacije - 1. del: Definicije, načela in pravila

Insulation co-ordination - Part 1: Definitions, principles and rules

Isolationskoordination - Teil 1: Begriffe, Grundsätze und Anforderungen

Coordination de l'isolation Partie 1: Définitions, principes et règles

Ta slovenski standard je istoveten z: [prEN IEC 60071-1:2026](https://standardsitic.si/)

ICS:

https://standardsitic.si/	01.040.29	Elektrotehnika (Slovarji)	prEN IEC 60071-1:2026	24f-e8	Electrical engineering	b0c1/osit-pren-iec-60071-1-2026
29.080.01		Električna izolacija na splošno			Electrical insulation in general	

oSIST prEN IEC 60071-1:2026

en



99/520/CDV

COMMITTEE DRAFT FOR VOTE (CDV)

PROJECT NUMBER:

IEC 60071-1 ED10

DATE OF CIRCULATION:

2026-01-02

CLOSING DATE FOR VOTING:

2026-03-27

SUPERSEDES DOCUMENTS:

99/491/CD, 99/503A/CC

IEC TC 99 : INSULATION CO-ORDINATION AND SYSTEM ENGINEERING OF HIGH VOLTAGE ELECTRICAL POWER INSTALLATIONS ABOVE 1,0 kV AC AND 1,5 kV DC

SECRETARIAT:	SECRETARY:
Australia	Ms Erandi Chandrasekare
OF INTEREST TO THE FOLLOWING COMMITTEES:	HORIZONTAL FUNCTION(S):
TC 8, TC 14, TC 17, SC 17A, SC 17C, SC 22F, SC 22G, TC 33, TC 36, TC 37, TC 38, TC 42, TC 115, TC 122	TC 99 Horizontal Basic
ASPECTS CONCERNED:	
Electricity transmission and distribution	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING
Attention IEC-CENELEC parallel voting The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) is submitted for parallel voting. The CENELEC members are invited to vote through the CENELEC online voting system.	

oSIST prEN IEC 60071-1:2026

<https://standards.iteh.ai/catalog/standards/sist/8d9cd24f-e8b0-4be9-974e-add74d07b0c1/osit-pren-iec-60071-1-2026>

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Recipients of this document are invited to submit, with their comments, notification of any relevant "In Some Countries" clauses to be included should this proposal proceed. Recipients are reminded that the CDV stage is the final stage for submitting ISC clauses. (SEE AC/22/2007 OR NEW GUIDANCE DOC).

TITLE:

Insulation co-ordination - Part 1: Definitions, principles and rules

PROPOSED STABILITY DATE: 2029

NOTE FROM TC/SC OFFICERS:

CONTENTS

2	FOREWORD	3
3	1 Scope	5
4	2 Normative references	5
5	3 Terms and definitions	6
6	4 Abbreviated terms and symbols	15
7	4.1 General	15
8	4.2 Subscripts	15
9	4.3 Letter symbols	15
10	4.4 Abbreviations	16
11	5 Procedure for insulation co-ordination	17
12	5.1 General outline of the procedure	17
13	5.2 Determination of the representative voltages and overvoltages (U_{rp})	18
14	5.3 Determination of the co-ordination withstand voltages (U_{cw})	19
15	5.4 Determination of the required withstand voltage (U_{rw})	19
16	5.5 Selection of the rated insulation level	20
17	5.6 List of standard rated short-duration power frequency withstand voltages	21
18	5.7 List of standard rated impulse withstand voltages	21
19	5.8 Ranges for highest voltage for equipment	21
20	5.9 Environmental conditions	21
21	5.9.1 Normal environmental conditions	21
22	5.9.2 Standard reference atmospheric conditions	21
23	5.10 Selection of the standard insulation level	22
24	5.11 Background of the standard insulation level	25
25	5.11.1 General	25
26	5.11.2 Standard rated switching impulse withstand voltage	26
27	5.11.3 Standard rated lightning impulse withstand voltage	26
28	6 Requirements for standard withstand voltage tests	26
29	6.1 General requirements	26
30	6.2 Standard short-duration power-frequency withstand voltage tests	27
31	6.3 Standard impulse withstand voltage tests	27
32	6.4 Alternative test situation	28
33	6.5 Phase-to-phase and longitudinal insulation standard withstand voltage tests for equipment in range I	28
34	6.5.1 Power-frequency tests	28
35	6.5.2 Phase-to-phase (or longitudinal) insulation lightning impulse tests	29
36	6.6 Phase-to-phase and longitudinal insulation standard withstand voltage tests for equipment in range II	29
37	Annex A (normative) Clearances in air to assure a specified impulse withstand voltage installation	30
38	A.1 General	30
39	A.2 Lightning impulse	30
40	A.3 Switching impulse	32
41	Annex B (informative) Rated insulation levels for highest voltages of equipment U_m not standardized by IEC	34
42	Bibliography	35

47		
48	Figure 1 – Flow chart for the determination of rated or standard insulation level	16
49		
50	Table 1 – Classes and shapes of overvoltages, Standard voltage shapes and Standard	
51	withstand voltage tests	17
52	Table 2 – Standard insulation levels for range I ($1 \text{ kV} < U_m \leq 245 \text{ kV}$)	22
53	Table 3 – Standard insulation levels for range II ($U_m > 245 \text{ kV}$)	23
54	Table A.1 – Correlation between standard rated lightning impulse withstand voltages	
55	and minimum air clearances	30
56	Table A.2 – Correlation between standard rated switching impulse withstand voltages	
57	and minimum phase-to-earth air clearances	30
58	Table A.3 – Correlation between standard rated switching impulse withstand voltages	
59	and minimum phase-to-phase air clearances	30
60	Table B.1 – Rated insulation levels for highest voltages of equipment U_m not	
61	standardized by IEC	30
62		
63		

iTeh Standards

(<https://standards.iteh.ai>)

Document Preview

[oSIST prEN IEC 60071-1:2026](#)

<https://standards.iteh.ai/catalog/standards/sist/8d9cd24f-e8b0-4be9-974e-add74d07b0c1/osist-pren-iec-60071-1-2026>