



SLOVENSKI STANDARD
oSIST prEN IEC 60079-2:2026
01-marec-2026

Eksplozivne atmosfere - 2. del: Zaščita opreme z nadtlakom "p"

Explosive atmospheres - Part 2: Equipment protection by pressurized enclosure "p"

Explosionsgefährdete Bereiche - Teil 2: Geräteschutz durch Überdruckkapselung "p"

Atmosphères explosives - Partie 2: Protection du matériel par enveloppe à surpression interne "p"

Ta slovenski standard je istoveten z: **prEN IEC 60079-2:2026**

ICS:

29.260.20

Električni aparati za
eksplozivna ozračja

Electrical apparatus for
explosive atmospheres

oSIST prEN IEC 60079-2:2026

en,fr,de



31/1947/CDV

COMMITTEE DRAFT FOR VOTE (CDV)

PROJECT NUMBER:

IEC 60079-2 ED7

DATE OF CIRCULATION:

2026-01-09

CLOSING DATE FOR VOTING:

2026-03-06

SUPERSEDES DOCUMENTS:

31/1764/CDV, 31/1942/RVC

IEC TC 31 : EQUIPMENT FOR EXPLOSIVE ATMOSPHERES	
SECRETARIAT: United Kingdom	SECRETARY: Mr Tom Stack
OF INTEREST TO THE FOLLOWING COMMITTEES:	HORIZONTAL FUNCTION(S):
ASPECTS CONCERNED:	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING Attention IEC-CENELEC parallel voting The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) is submitted for parallel voting. The CENELEC members are invited to vote through the CENELEC online voting system.	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Recipients of this document are invited to submit, with their comments, notification of any relevant "In Some Countries" clauses to be included should this proposal proceed. Recipients are reminded that the CDV stage is the final stage for submitting ISC clauses. (SEE [AC/22/2007](#) OR [NEW GUIDANCE DOC](#)).

TITLE:

Explosive atmospheres – Part 2: Equipment protection by pressurized enclosure "p"

PROPOSED STABILITY DATE: 2029

NOTE FROM TC/SC OFFICERS:

The MT has requested a second CDV, with the instruction that comments should be limited to confirming that no unintended issues have been introduced during the updates made in response to the first CDV.

No new technical comments should be submitted at this stage; any new technical input will be held for consideration in the next edition. The rationale for this is that, should anything have been overlooked or inadvertently affected during the latest revisions, addressing it at the CDV stage is significantly more efficient.

Copyright © 2026 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

IEC CDV 60079-2 © IEC 2026

CONTENTS

FOREWORD.....	6
1 Scope.....	16
2 Normative references	21
3 Terms and definitions	21
4 Levels of Protection.....	24
5 Constructional requirements for pressurized enclosures	27
5.1 Enclosure	27
5.1.1 General	27
5.1.2 Incorporating EPL Gc Ex Equipment or Ex Components	27
5.2 Materials.....	27
5.3 Doors and covers	27
5.3.1 General	27
5.3.2 Group I pressurized enclosures	28
5.3.3 Group I pressurized enclosures with static pressurization	28
5.3.4 Group II and Group III pressurized enclosures	28
5.3.5 Group II and Group III pressurized enclosures with static pressurization	28
5.3.6 Group II and Group III Level of Protection "pxb"	28
5.3.7 Group II and Group III door and cover warning	28
5.4 Mechanical strength.....	28
6 Constructional requirements for pressurized equipment.....	28
6.1 Group I and Group II apertures, and partitions	28
6.2 Group I and Group II internal components, compartments, and enclosures	29
6.3 Apertures for static pressurization.....	29
6.4 Insulating materials for Group I equipment.....	29
6.5 Spark and particle barriers.....	30
6.6 Bypass or override function.....	30
7 Temperature limits.....	30
7.1 General.....	30
7.2 For Level of Protection "pxb" or Level of Protection "pyb"	30
7.3 For Level of Protection "pzc"	31
8 Safety devices and control functions of pressurization control systems (except for static pressurization)	31
8.1 General.....	31
8.2 Provider of safety devices	33
8.3 Pressurization Control Systems	33
8.3.1 General	33
8.3.2 For Level of Protection "pzc"	33
8.3.3 For Level of Protection "pyb"	34
8.3.4 For Level of Protection "pxb"	34
8.3.5 Evaluated as Ex associated equipment.....	34
8.4 Group I and Group II Purging for Level of Protection "pxb"	35
8.5 Group I or Group II – Purging criteria	35
8.6 Group III – Cleaning.....	36
8.7 Requirements when a minimum flow rate required	36

IEC CDV 60079-2 © IEC 2026

8.8	Safety devices to detect minimum pressurization overpressure	37
8.9	Value of pressurization overpressure and maximum overpressure	37
8.10	Pressurizing multiple enclosures	38
8.11	Safety devices on doors and covers	38
8.12	Equipment that may remain powered	39
8.13	Equipment permitted within Level of Protection "pyb"	39
9	Safety provisions and safety devices for static pressurization	39
9.1	Suitability of safety devices for hazardous area	39
9.2	Protective gas	39
9.3	Internal sources of release	39
9.4	Group I and Group II Filling procedure	39
9.5	Group III Filling Procedure	40
9.6	Safety devices	40
9.7	Equipment that may remain powered	40
9.8	Overpressure	40
10	Supply of protective gas	40
10.1	Backup supply	40
10.2	Independent supplies	41
10.3	Types of gas	41
10.4	Temperature	41
11	Pressurized equipment with an internal source of release	41
11.1	General	41
11.2	Release conditions	43
11.2.1	No release	43
11.2.2	Limited release of a gas or vapour	43
11.2.3	Limited release of a liquid	43
11.3	Design requirements for the containment system	43
11.3.1	General design requirements	43
11.3.2	Infallible containment system	44
11.3.3	Containment system with a limited release	44
11.3.4	Limiting of flammable substance flow	45
11.3.5	Containment systems with a flame	45
11.4	Protective gas and pressurizing techniques when there is an internal source of release	45
11.4.1	General	45
11.4.2	Pressurization with leakage compensation	46
11.4.3	Pressurization with dilution flow	46
11.5	Equipment in undiluted volume	47
11.6	Internal hot surfaces	47
12	Cells and batteries within pressurized equipment	48
12.1	General Requirements	48
12.2	Cells or batteries used for memory backup applications	48
12.3	Other cell and battery types	48
12.4	Cell and battery related warnings	48
12.4.1	General	48
12.4.2	Relevant to EPL Mb, Gb or Db without other protection	48
12.4.3	Relevant to EPL Gc or Dc without other protection	49

IEC CDV 60079-2 © IEC 2026

12.4.4	Otherwise protected.....	49
13	Type Verification and Tests	49
13.1	General.....	49
13.2	Verification of the maximum overpressure rating	49
13.3	Maximum overpressure test	49
13.4	Leakage test	50
13.4.1	Other than static pressurization	50
13.4.2	Static pressurization	50
13.5	Purging and dilution flow tests	50
13.5.1	General	50
13.5.2	Criteria for compliance where the protective gas is air	51
13.5.3	Criteria for compliance where the protective gas is inert	51
13.6	Purging test for pressurized equipment with no internal source of release and filling procedure test for static pressurization	51
13.6.1	General	51
13.6.2	Pressurized equipment where the protective gas is air.....	51
13.6.3	Pressurized equipment where the protective gas is inert.....	51
13.6.4	Pressurized equipment where the protective gas may be either air or an inert gas with a density equal to air $\pm 10\%$	52
13.6.5	Filling procedure test for a pressurized equipment protected by static pressurization.....	52
13.7	Purging and dilution flow tests for a pressurized equipment with an internal source of release	52
13.7.1	Test gas	52
13.7.2	Pressurized equipment where the flammable substance has less than a volume fraction of 2 % oxygen and the protective gas is inert	52
13.7.3	Pressurized equipment with pressurization by continuous flow, containment system with less than a volume fraction of 21 % oxygen and the protective gas is inert.....	52
13.7.4	Pressurized equipment where the flammable substance is not a liquid, pressurization by continuous flow and the protective gas is air	53
13.8	Verification of minimum pressurization overpressure.....	54
13.9	Tests for an infallible containment system	54
13.9.1	Overpressure test	54
13.9.2	Infallibility test	54
13.10	Overpressure test for a containment system with a limited release	54
13.11	Pressurization Control Systems	55
14	Routine tests	55
14.1	Functional test	55
14.2	Leakage test	55
14.3	Tests for an infallible containment system.....	55
14.4	Test for a containment system with a limited release	55
15	Marking	55
15.1	General.....	55
15.2	Identifying as pressurized	55
15.3	Supplementary marking	55
15.4	Internal source of release	56
15.5	Static pressurization	56

IEC CDV 60079-2 © IEC 2026

15.6	Pressurization control systems evaluated as Ex associated equipment	56
15.7	Inert gas	57
15.8	Internal flammable substance	57
15.9	Warning markings	57
15.10	Examples of marking	58
16	Schedule drawings	60
17	Instructions	61
Annex A (informative) Design considerations for pressurized equipment that have containment systems where the flammable material is a liquid		63
A.1	General	63
A.2	Classification of material state	63
A.3	Design recommendations	63
A.3.1	Flashing liquids	63
A.3.2	Pooling liquids	63
A.3.3	Leak Detection	63
A.3.4	Isolation of flammable lines	64
A.3.5	Drain & vent connections	64
A.3.6	Flame detectors	64
A.4	Dilution vs leakage compensation	64
Annex B (informative) Examples of functional sequence diagram		65
B.1	Information to User	65
Annex C (informative) Examples of the changes in pressure in ducts and enclosures		67
Annex D (informative) Information intended to be provided to the user		72
D.1	General	72
D.2	Ducting of protective gas	72
D.2.1	Location of inlet	72
D.2.2	Ducting between pressurized equipment and inlet	72
D.2.3	Outlets for protective gas	72
D.2.4	Additional purge time to account for ducting	73
D.2.5	Temperature of protective gas at the inlet	73
D.3	Power for protective gas supply	73
D.4	Static pressurization	73
D.5	Pressurized Equipment with a containment system	73
D.6	Pressurized Equipment maximum overpressure	73
Annex E (normative) Classification of the type of release within pressurized equipment		74
E.1	General	74
E.2	No normal release, no abnormal release	74
E.3	No normal release, limited abnormal release	74
E.4	Limited normal release	74
Annex F (informative) Examples for the use of the diluted volume concept		75
Annex G (informative) Evaluation of control functions and expected malfunctions		78
Bibliography		81
Figure 1 – Determination of Level of Protection		25
Figure 2 – Determination of protection level and protective gas for equipment with internal release		42