

---

**Varnostne zahteve za električno opremo za meritve, nadzor in laboratorijsko uporabo - 2-033. del: Posebne zahteve za ročne multimetre in druge merilnike za domačo in profesionalno uporabo, ki omogočajo merjenje omrežne napetosti**

Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-033: Particular requirements for hand-held multimeters and other meters for domestic and professional use, capable of measuring mains voltage

Sicherheitsbestimmungen für elektrische Mess-, Steuer-, Regel- und Laborgeräte - Teil 2-033: Besondere Anforderungen an handgehaltene Multimeter und andere Messgeräte für den Haushalt und professionellen Gebrauch, geeignet zur Messung von Netzspannungen

get full document from [standards.iteh.ai](https://standards.iteh.ai)

Exigences de sécurité pour appareils électriques de mesure, de régulation et de laboratoire - Partie 2-033: Exigences particulières pour les multimètres portatifs pour usage domestique et professionnel, capables de mesurer la tension réseau

**Ta slovenski standard je istoveten z: prEN IEC 61010-2-033:2026**

---

**ICS:**

|           |  |   |
|-----------|--|---|
| 19.080    | Električno in elektronsko preskušanje        | Electrical and electronic testing           |
| 71.040.10 | Kemijski laboratoriji. Laboratorijska oprema | Chemical laboratories. Laboratory equipment |

**oSIST prEN IEC 61010-2-033:2026**      **en,fr,de**

# Sample Document

get full document from [standards.iteh.ai](https://standards.iteh.ai)



# 66/876/CDV

## COMMITTEE DRAFT FOR VOTE (CDV)

|  |   |
|--|---|
| PROJECT NUMBER:<br><b>IEC 61010-2-033 ED4</b>        |   |
| DATE OF CIRCULATION:<br><b>2026-03-13</b>            | CLOSING DATE FOR VOTING:<br><b>2026-06-05</b> |
| SUPERSEDES DOCUMENTS:<br><b>66/866/CD, 66/871/CC</b> |   |

|   |  |
|---|--|
| IEC TC 66 : SAFETY OF MEASURING, CONTROL AND LABORATORY EQUIPMENT   |  |
| SECRETARIAT:<br>United Kingdom  | SECRETARY:<br>Ms Stephanie Lavy                                    |
| OF INTEREST TO THE FOLLOWING COMMITTEES:<br>TC 78, TC 85  | HORIZONTAL FUNCTION(S):  |
| ASPECTS CONCERNED:<br>Safety  |  |
| <input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING   | <input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING |
| <p><b>Attention IEC-CENELEC parallel voting</b></p> <p>The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) is submitted for parallel voting.</p> <p>The CENELEC members are invited to vote through the CENELEC online voting system.</p> |  |

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Recipients of this document are invited to submit, with their comments, notification of any relevant "In Some Countries" clauses to be included should this proposal proceed. Recipients are reminded that the CDV stage is the final stage for submitting ISC clauses. (SEE [AC/22/2007](#) OR [NEW GUIDANCE DOC](#)).

TITLE:

**Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-033: Particular requirements for hand-held multimeters and other meters for domestic and professional use, capable of measuring mains voltage**

PROPOSED STABILITY DATE: 2031

NOTE FROM TC/SC OFFICERS:

**Copyright © 2026 International Electrotechnical Commission, IEC.** All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

## IEC CDV 61010-2-033 © IEC 2026

|    |  |    |
|----|--|----|
| 1  | <b>CONTENTS</b>  |    |
| 2  | FOREWORD.....  | 3  |
| 3  | INTRODUCTION .....   | 6  |
| 4  | 1 Scope and object .....   | 7  |
| 5  | 2 Normative references.....  | 8  |
| 6  | 3 Terms, definitions and abbreviated terms.....  | 8  |
| 7  | 4 Assessment, tests, and environmental conditions .....  | 10 |
| 8  | 5 Marking and documentation.....   | 11 |
| 9  | 6 Protection against electric shock .....  | 14 |
| 10 | 7 Protection against mechanical HAZARDS .....  | 19 |
| 11 | 8 Resistance to mechanical stresses .....  | 19 |
| 12 | 9 Protection against the spread of fire and arc flash .....  | 19 |
| 13 | 10 Equipment temperature limits and resistance to temperature .....                                    | 25 |
| 14 | 11 Protection against HAZARDS from fluids and solid foreign objects.....                               | 25 |
| 15 | 12 Protection against injury from radiation, sonic and ultrasonic pressure.....                        | 25 |
| 16 | 13 Protection against hazardous substances, explosion and implosion.....                               | 25 |
| 17 | 14 Components and subassemblies .....  | 25 |
| 18 | 15 Interlocks and safety-related controls.....   | 27 |
| 19 | 16 Protection against HARM related to the use of the equipment.....                                    | 27 |
| 20 | 17 Assessment of RISKS and situations not fully covered by Clauses 6-16.....                           | 29 |
| 21 | Annex K (normative) Insulation requirements not covered by 6.7.....                                    | 30 |
| 22 | Annex L (informative) Index of defined terms.....  | 39 |
| 23 | Annex P (normative) Not used.....  | 40 |
| 24 | Annex AA (normative) MEASUREMENT CATEGORIES .....  | 41 |
| 25 | Annex BB (informative) MEASURING CIRCUITS .....  | 44 |
| 26 | Annex CC (informative) HAZARDS pertaining to measurements performed in certain<br>27 environments..... | 46 |
| 28 | Annex DD (informative) 4 mm "banana" TERMINALS.....  | 49 |
| 29 | Annex EE (informative) Flowchart for insulation according to the type of MEASURING<br>30 CIRCUIT.....  | 51 |
| 31 | Annex FF (informative) Determination of CLEARANCES for Table 102.....                                  | 54 |
| 32 | Bibliography .....   | 55 |
| 33 | Figure 4 – Acceptable arrangement of protective means against electric shock.....                      | 15 |
| 34 | Figure AA.1 – Example to identify the locations of MEASUREMENT CATEGORIES .....                        | 43 |
| 35 | Figure DD.1 – Recommended dimensions of 4 mm TERMINALS.....  | 51 |
| 36 | Figure EE.1 – Requirements for CLEARANCE, CREEPAGE DISTANCE and solid insulation.....                  | 54 |
| 37 | Table 0.1 – IEC 61010 standards to be applied in case of combined equipment.....                       | 7  |
| 38 | Table 101 – Abbreviated terms.....   | 11 |
| 39 | Table 102 – CLEARANCES for unmated MEASURING CIRCUIT TERMINALS .....                                   | 17 |
| 40 | Table 102 – Impulse voltages for circuits connected to MAINS .....                                     | 25 |
| 41 | Table 27 – Bridging insulation by IEC 60384-14 subclass Y capacitors.....                              | 27 |

## IEC CDV 61010-2-033 © IEC 2026

|    |  |    |
|----|--|----|
| 42 | Table K.15 – CLEARANCE values for the calculation of K.3.2 .....                     | 33 |
| 43 | Table K.16 – Test voltages based on CLEARANCES.....                                  | 34 |
| 44 | Table K.101 – CLEARANCES for MEASURING CIRCUITS .....                                | 36 |
| 45 | Table K.102 – Impulse test voltages for solid insulation in MEASURING CIRCUITS ..... | 37 |
| 46 | Table K.103 – AC test voltages for solid insulation in MEASURING CIRCUITS .....      | 37 |
| 47 | Table K.104 – Minimum values for distance or thickness of solid insulation in        |    |
| 48 | MEASURING CIRCUITS .....   | 38 |
| 49 | Table AA.1 – Characteristics of MEASUREMENT CATEGORIES .....                         | 44 |
| 50 | Table FF.1 – CLEARANCE values for Table 102.....                                     | 55 |

# Sample Document

get full document from [standards.iteh.ai](https://standards.iteh.ai)

## 51 INTERNATIONAL ELECTROTECHNICAL COMMISSION

52 **SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT**  
53 **FOR MEASUREMENT, CONTROL, AND LABORATORY USE –**54 **Part 2-033: Particular requirements for hand-held multimeters**  
55 **and other meters for domestic and professional use,**  
56 **capable of measuring mains voltage**

## 57 FOREWORD

- 58 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising  
59 all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international  
60 co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and  
61 in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports,  
62 Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their  
63 preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with  
64 may participate in this preparatory work. International, governmental and non-governmental organizations liaising  
65 with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for  
66 Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 67 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international  
68 consensus of opinion on the relevant subjects since each technical committee has representation from all  
69 interested IEC National Committees.
- 70 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National  
71 Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC  
72 Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any  
73 misinterpretation by any end user.
- 74 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications  
75 transparently to the maximum extent possible in their national and regional publications. Any divergence between  
76 any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 77 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity  
78 assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any  
79 services carried out by independent certification bodies.
- 80 6) All users should ensure that they have the latest edition of this publication.
- 81 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and  
82 members of its technical committees and IEC National Committees for any personal injury, property damage or  
83 other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and  
84 expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC  
85 Publications.
- 86 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is  
87 indispensable for the correct application of this publication.
- 88 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent  
89 rights. IEC shall not be held responsible for identifying any or all such patent rights.

90 IEC 61010-2-033 has been prepared by IEC technical committee 66: Safety of measuring,  
91 control and laboratory equipment. It is an International Standard.

92 This fourth edition cancels and replaces the third edition published in 2023. This edition  
93 constitutes a technical revision.

94 This edition includes the following significant technical changes with respect to the previous  
95 edition:

- 96 a) IEC 61010-2-130 has been considered relevant to this document;  
97 b) added a definition for MEASURING CIRCUITS;  
98 c) impact of amendment 2 to IEC 61010-1:2010+A1:2016 has been taken into consideration:  
99 1) Clause 2 and Bibliography have been updated;

## IEC CDV 61010-2-033 © IEC 2026

- 100 2) MAINS definition has been modified;
- 101 3) modifications of 6.8.3.1 and 6.8.3.2 have been deleted since Amendment 2 of IEC 61010  
102 1 take them now into account;
- 103 4) conformity statements of K.3.2 and K.101.2 have been modified;
- 104 5) a few conformity statements for constructional requirements of solid insulation have  
105 been modified;
- 106 d) definition of measurement category has been modified, added a definition for MEASURING  
107 CIRCUITS and HIGH INTEGRITY component (see also 14.102);
- 108 e) added a new 3.101 for abbreviated terms and a Table 101;
- 109 f) in 4.4.2.101, requirements for surge protective components have been modified;
- 110 g) in 5.1.5.101 markings of TERMINALS for MEASUREMENT CATEGORIES have been completed,  
111 including the nature of the voltage AC or DC only which is now explicitly permissible;
- 112 h) in 6.6.101.1, a new requirement for TERMINALS is added;
- 113 i) in 6.6.101.2, the conformity statement has been modified;
- 114 j) in 6.8.1, a precision is given when testing solid insulation;
- 115 k) subclause 9.1 has been modified;
- 116 l) 9.101.1 and 9.101.2.1 have been redrafted for clarification, in particular to take into account  
117 the recommendations of new Annex N about REASONABLY FORESEEABLE MISUSE;
- 118 m) requirements for capacitors have been added to 14.9;
- 119 n) requirements for HIGH INTEGRITY component have been added to a new 14.102;
- 120 o) Clause 101 has been deleted and replaced by a new Annex BB:
- 121 1) 101.2 has been moved to 9.101.4 as this subclause is relevant for prevention of spread  
122 of fire;
- 123 2) protection of current MEASURING CIRCUITS has been completed in 9.101.4.1;
- 124 3) 101.3 has been moved to 16.4 and 16.101;
- 125 p) installation limit of CAT IV has been modified in Figure AA.1;
- 126 q) a new Annex BB for MEASURING CIRCUIT has been added; other annexes have been  
127 renumbered.

128 The text of this International Standard is based on the following documents:

| Draft       | Report on voting |
|-------------|------------------|
| 66/xxx/FDIS | 66/xxx/RVD       |

129 Full information on the voting for its approval can be found in the report on voting indicated in  
130 the above table.

131 The language used for the development of this International Standard is English.

132 This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in  
133 accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available  
134 at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are  
135 described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

136 A list of all parts of the IEC 61010 series, under the general title *Safety requirements for*  
137 *electrical equipment for measurement, control, and laboratory use*, can be found on the IEC  
138 website.

## IEC CDV 61010-2-033 © IEC 2026

139 This document is to be used in conjunction with IEC 61010-1:2010,  
140 IEC 61010-1:2010/AMD1:2016 and IEC 61010-1:2010/AMD2:—<sup>1</sup>.

141 This document supplements or modifies the corresponding clauses in IEC 61010-1 so as to  
142 convert that publication into the IEC standard: *Particular requirements for hand-held*  
143 *multimeters and other meters for domestic and professional use, capable of measuring mains*  
144 *voltage*.

145 Where a particular subclause of IEC 61010-1 is not mentioned in this document, that subclause  
146 applies as far as is reasonable. Where this document states "addition", "modification",  
147 "replacement", or "deletion" the relevant requirement, test specification or note in IEC 61010-1  
148 should be adapted accordingly.

149 In this standard:

150 a) the following print types are used:

- 151 – requirements: in roman type;
- 152 – NOTES: in small roman type;
- 153 – *conformity and tests: in italic type*;
- 154 – terms used throughout this standard which have been defined in Clause 3: SMALL ROMAN  
155 CAPITALS;

156 a) subclauses, figures, tables and notes which are additional to those in IEC 61010-1 are  
157 numbered starting from 101. Additional annexes are lettered starting from AA and additional  
158 list items are lettered from aa).

159 The committee has decided that the contents of this document will remain unchanged until the  
160 stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the  
161 specific document. At this date, the document will be

- 162 • reconfirmed,
- 163 • withdrawn,
- 164 • replaced by a revised edition, or
- 165 • amended.

166

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

<sup>1</sup> Second amendment under preparation. Stage at the time of publication: IEC FDIS 61010-1/AMD2:2026.

## IEC CDV 61010-2-033 © IEC 2026

167

## INTRODUCTION

168 IEC 61010-1 specifies the safety requirements that are generally applicable to all equipment  
 169 within its scope. For certain types of equipment, the requirements of IEC 61010-1 and its  
 170 amendments will be supplemented or modified by the special requirements of one or more  
 171 standard from the IEC 61010-2 series which is/are read in conjunction with the requirements of  
 172 IEC 61010-1.

173 This document and IEC 61010-2-030, IEC 61010-2-032 and IEC 61010-2-034 specify the safety  
 174 requirements for equipment with testing or MEASURING CIRCUITS which are connected for test or  
 175 measurement purposes to devices or circuits outside the measurement equipment itself.

176 According to the type of equipment and combination of functions, several IEC 61010 standards  
 177 are used in conjunction (see Table 0.1).

178 **Table 0.1 – IEC 61010 standards to be applied in case of combined equipment**

| Type of equipment (example)  | Applicable IEC 61010 standards | Additional standards to be applied in case of combined equipment with additional features or equipment designed for specific use |                                |  |                                    |  |  |
|--|--------------------------------|--|--------------------------------|--|------------------------------------|--|--|
|  |                                | Hand-held current sensing  | Multimeter function            | Insulation resistance test or measurement function | Other measuring and test functions | Hand-held and hand-manipulated probe     | Equipment used in educational establishment by pupil OPERATORS |
| Hand-held and hand-manipulated current sensors                     | Part 1 + Part 2-032            | Function included in the scope   | Part 2-033 is included         | Part 2-034 is used in conjunction                  | Other functions are included       | Part 031 applies to relevant accessories | Part 2-130 is used in conjunction                              |
| Hand-held multimeters and other meters for measuring MAINS voltage | Part 1 + Part 2-033            | Part 2-032 supersedes  | Function included in the scope | Part 2-034 is used in conjunction                  | It depends                         |  |  |
| Insulation resistance and test equipment for electric strength     | Part 1 + Part 2-034            | Part 2-032 is used in conjunction  | Not apply                      | Function included in the scope                     | Other functions are included       |  |  |
| Other equipment having testing or measuring circuits               | Part 1 + Part 2-030            | Part 2-032 is used in conjunction  | It depends                     | Part 2-034 supersedes                              | Functions included in the scope    |  |  |

179 **SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT**  
 180 **FOR MEASUREMENT, CONTROL, AND LABORATORY USE –**

181 **Part 2-033: Particular requirements for hand-held multimeters**  
 182 **and other meters for domestic and professional use,**  
 183 **capable of measuring mains voltage**

184 *All Clauses and their subclauses, all Annexes, their Clauses and subclauses, and Bibliography*  
 185 *of IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016 and IEC 61010-1:2010/AMD2:—<sup>2</sup> apply*  
 186 *except as follows.*

187 **1.1.1 Equipment included in scope**

188 *Replace the existing text of 1.1.1 with the following new text:*

189 This part of IEC 61010 specifies safety requirements for hand-held multimeters and other  
 190 meters for domestic and professional use, capable of measuring MAINS.

191 Hand-held multimeters are multi-range multifunction measuring instruments intended to  
 192 measure voltage and other electrical quantities such as resistance or current. Their primary  
 193 purpose is to measure voltage on a live MAINS. They are suitable to be supported by one hand  
 194 during NORMAL USE.

get full document from standards.iteh.ai

195 **1.1.2 Equipment excluded from scope**

196 *Add the following new item to the list of 1.1.2 and the following new paragraph:*

197 aa) IEC 61557 (all parts), *Electrical safety in low voltage distribution systems up to*  
 198 *1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of*  
 199 *protective measures.*

200 HAND-HELD EQUIPMENT such as oscilloscopes, wattmeters, process control multimeters not  
 201 RATED for measuring voltage on a live MAINS, clamp multimeters and communications test sets  
 202 are not within the scope of this document.

203 **Aspects included in scope** *Replace item c) and item h) from the list of the second paragraph of*  
 204 *1.2.1 with the following new item c) and item h):*

- 205 c) spread of fire or arc flash from the hand-held multimeters (see Clause 9);  
 206 h) HAZARDS related to the use and REASONABLY FORESEEABLE MISUSE of the hand-held  
 207 multimeter (see Clause 16 and Annex BB).

208 *Insert the following new paragraph between the third paragraph and the NOTE of 1.2.1:*

<sup>2</sup> Second amendment under preparation. Stage at the time of publication: IEC FDIS 61010-1/AMD2:2026.

209 Annex BB and Annex CC provides guidance to equipment manufacturers on HAZARDS that  
 210 should be considered for equipment intended for performing tests and measurements on  
 211 hazardous conductors, including MAINS conductors and telecommunication network conductors.

## 212 **1.2.2 Aspects excluded from scope**

213 *Add a new item aa) after item h) of the list of 1.2.2:*

214 aa) HAZARDS related to the use by pupil OPERATORS in educational establishments (see  
 215 IEC 61010-2-130).

## 216 **2 Normative references**

217 *Insert the following six new normative references in Clause 2:*

218 IEC 60364-4-44:2024, *Low-voltage electrical installations – Part 4-44: Protection for safety –*  
 219 *Protection against voltage disturbances and electromagnetic disturbances*

220 IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control, and*  
 221 *laboratory use – Part 1: General requirements*

222 IEC 61010-1:2010/AMD1:2016

223 IEC 61010-1:2010/AMD2:—<sup>3</sup>

224 IEC 61010-2-030:—<sup>4</sup>, *Safety requirements for electrical equipment for measurement, control,*  
 225 *and laboratory use – Part 2-030: Special requirements for testing and measuring circuits*

226 IEC 61010-2-032:—<sup>5</sup>, *Safety requirements for electrical equipment for measurement, control,*  
 227 *and laboratory use – Part 2-032: Particular requirements for hand-held and hand-manipulated*  
 228 *current sensors for electrical test and measurement*

229 IEC 61010-031:2022, *Safety requirements for electrical equipment for measurement, control and*  
 230 *laboratory use – Part 031: Safety requirements for hand-held probe assemblies for electrical*  
 231 *measurement and test*

232 *Replace the existing title of Clause 3 with the following new title:*

## 233 **3 Terms, definitions and abbreviated terms**

234 *Add the following new term and definition after 3.2.5:*

<sup>3</sup> Second amendment under preparation. Stage at the time of publication: IEC FDIS 61010-1/AMD2:2026.

<sup>4</sup> Sixth edition under preparation. Stage at the time of publication: IEC CDV 61010-2-030:2026.

<sup>5</sup> Sixth edition under preparation. Stage at the time of publication: IEC CDV 61010-2-032:2026.

## IEC CDV 61010-2-033 © IEC 2026

235 **3.2.101**  
 236 **MEASURING CIRCUIT**  
 237 testing or measuring circuit (internal to the hand-held multimeter) which is connected for test or  
 238 measurement purposes to devices or circuits outside the hand-held multimeter itself

239 *Replace the definition of 3.5.4 with the following new definition:*

240 **3.5.4**  
 241 **MAINS**  
 242 AC or DC electrical power distribution system (external to the equipment)

243 NOTE 1 to entry: MAINS include public or private electrical utilities and, unless otherwise specified in this document,  
 244 equivalent sources such as motor-driven generators and uninterruptible power supplies.

245 NOTE 2 to entry: This definition differs from the IEC 61010-1:2010/AMD2:— definition by allowing voltages greater  
 246 than 1 000 V AC and 1 500 V DC and MAINS can be used to power the equipment or be measured.

247 *Add the following two new terms and definitions after 3.5.24:*

248 **3.5.101**  
 249 **HIGH INTEGRITY**  
 250 providing a degree of protection against HAZARDS equivalent to two levels of protection

251 NOTE 1 to entry: A HIGH INTEGRITY part is considered as not subject to failure when tests under fault conditions are  
 252 made.

253 NOTE 2 to entry: See reinforced protection defined in IEC 60050-903:2013, 903-02-08.

254 **3.5.102**  
 255 **MEASUREMENT CATEGORY**  
 256 numeral defining MEASURING CIRCUITS according to the type of MAINS to which they are intended  
 257 to be connected

## IEC CDV 61010-2-033 © IEC 2026

258 *Add the new following 3.101 and a new Table 101 after 3.6:*

259 **3.101 Abbreviated terms**

260 The list of abbreviated terms used in this document is given in Table 101.

261 **Table 101 – Abbreviated terms**

| Abbreviated term | Term                                | Note  |
|------------------|-------------------------------------|---|
| AC               | alternating current                 | Pertaining to alternating electric quantities such as voltage or current, to devices operated with these, or to quantities associated with these devices (IEC 60050-151:2001, 151-15-01, modified).                           |
| DC               | direct current                      | Pertaining to time-independent electric quantities such as voltage or current, to devices operated with direct voltage and current, or to quantities associated with these devices (IEC 60050-151:2001, 151-15-02, modified). |
| RMS              | root-mean-square                    | For a time-dependent quantity, positive square root of the mean value of the square of the quantity taken over a given time interval (IEC 60050-103:2009/AMD1:2017, 103-02-03, modified).                                     |
| SPC              | surge protective component          | Components for low-voltage surge protective devices (SPD) described in IEC 61643 series such as IEC 61643-311, IEC 61643-331, IEC 61643-341.  |
| OVC              | OVERVOLTAGE CATEGORY                | "OVC" precedes the OVERVOLTAGE CATEGORY numeral.  |
| CAT              | MEASUREMENT CATEGORY                | "CAT" precedes the MEASUREMENT CATEGORY numeral.  |
| $D_1$            | CLEARANCE for TRANSIENT OVERVOLTAGE | $D_1$ is the CLEARANCE that would be applicable to a TRANSIENT OVERVOLTAGE with the shape of a $1,2 \times 50 \mu\text{s}$ impulse (see K.3.2).   |
| $D_2$            | CLEARANCE for WORKING VOLTAGE       | $D_2$ is the CLEARANCE that would be applicable to the peak WORKING VOLTAGE without any TRANSIENT OVERVOLTAGE (see K.3.2).  |
| $U_m$            | maximum peak value                  | $U_m$ is maximum peak value of the working voltage plus the maximum additional transient overvoltage (see K.3.2).   |

262 **4.3.2.6 Input and output voltages**

263 *Replace the existing title and text of 4.3.2.6 with the following new title and text:*

264 **4.3.2.6 Input and output voltages or currents**

265 Input and output voltages or currents, including floating voltages but excluding the electrical  
266 supply source (see 4.3.2.5), shall be set to any voltage or current within their RATED range, in  
267 normal and reverse polarity if possible.

268 **4.4.2.1 General**

269 *Replace the item 2) of the first paragraph of 4.4.2.1 with the following new item 2):*

270 2) Applicable fault conditions specified in 4.4.2.2 to 4.4.2.15 and 4.4.2.101;

271 *Add the following 4.4.2.101 after 4.4.2.15:*

272 **4.4.2.101 Surge protective components (SPC)**

273 SPC used in MAINS CIRCUITS or MEASURING CIRCUITS connected to MAINS shall be short-circuited  
274 and open-circuited, only one at a time in turn in any convenient order.

275 **5.1.2 Identification**

276 *Add the following new NOTE 101 after the existing NOTE of 5.1.2:*

277 NOTE 101 Some national regulations can require a marking to indicate the name and edition of the standard used  
278 for compliance evaluation.

279 **5.1.5.1 General**

280 *Replace the first paragraph of 5.1.5.1 with the following:*

281 If necessary for safety, an indication shall be given of the purpose of TERMINALS, connectors,  
282 controls, and indicators. Where there is insufficient space, symbol 14 from Table 1 may be used.

283 **5.1.5.2 TERMINALS**

284 *Replace the existing item d) of 5.1.5.2 with the following new item d):*

285 d) TERMINALS supplied from the interior of the hand-held multimeter and which could be  
286 HAZARDOUS LIVE, with the voltage, current, charge or energy value or range, or with  
287 symbol 12 of Table 1;

288 *Add the following new item to the list of 5.1.5.2:*

289 aa) TERMINALS supplied from other TERMINALS which could be HAZARDOUS LIVE, with  
290 symbol 12 or symbol 14 of Table 1.

291 *Add the following 5.1.5.101 after 5.1.5.2:*

292 **5.1.5.101 MEASURING CIRCUIT TERMINALS**

293 **5.1.5.101.1 General**

294 MEASURING CIRCUIT TERMINALS are usually arranged in pairs or sets. Each pair or set of  
295 TERMINALS may have a RATED voltage or a RATED current, or both, within that set, and each  
296 individual TERMINAL will have a RATED voltage to earth. For some hand-held multimeters, the  
297 RATED voltage between TERMINALS may be different from the RATED voltage to earth. Markings  
298 shall be clear to avoid misunderstanding.

299 Each pair or set of MEASURING CIRCUIT TERMINALS that are intended to be used together shall be  
300 marked with the value of the RATED voltage or the RATED current as applicable to the pair or set  
301 of TERMINALS.

## IEC CDV 61010-2-033 © IEC 2026

302 MEASURING CIRCUIT TERMINALS RATED for MEASUREMENT CATEGORIES shall be marked as specified  
303 in 5.1.5.102.2.

304 MEASURING CIRCUIT TERMINALS that do not have a RATING for connection to voltages above the  
305 levels of 6.3.1, may be marked with alternative markings.

306 MEASURING CIRCUIT TERMINALS which are dedicated only for connection to specific TERMINALS of  
307 other equipment does not need to be marked provided that there is a means of identifying these  
308 TERMINALS.

309 TERMINAL markings shall be visible when the hand-held multimeter is ready for NORMAL USE with  
310 connectors and TERMINALS mated and shall reference the applicable TERMINALS.

311 *Conformity is checked by inspection.*

### 312 **5.1.5.101.2 MEASURING CIRCUIT TERMINALS RATED FOR MEASUREMENT CATEGORIES**

313 TERMINALS of MEASURING CIRCUITS RATED for MEASUREMENT CATEGORIES shall be marked with the  
314 numeral of the MEASUREMENT CATEGORY and the nominal AC RMS line-to-neutral or DC voltage  
315 of the MAINS RATED for the MEASUREMENT CATEGORY.

316 1) The numeral of the MEASUREMENT CATEGORY markings shall be marked "CAT III" or "CAT IV"  
317 as applicable.

318 Marking of MEASUREMENT CATEGORY II ("CAT II") is not allowed.

319 2) The nominal AC RMS line-to-neutral or DC voltage of MAINS being measured is the voltage  
320 to earth for MEASUREMENT CATEGORIES. It is taken from the following list:

321 300 V, 600 V, 1 000 V, 1 500 V, 2 000 V and 3 000 V.

322 Marking those TERMINALS with the nature AC or DC of the nominal AC RMS line-to-neutral  
323 or DC voltage of the MAINS RATED for the MEASUREMENT CATEGORY only is permissible.

324 NOTE CLEARANCES and solid insulation for MEASUREMENT CATEGORIES are RATED for a nominal AC RMS line-  
325 to-neutral voltage or a DC voltage of MAINS. Neutral is considered to be earthed (see K.101.2, K.101.4 and  
326 Annex I).

327 Marking those TERMINALS with more than one numeral of MEASUREMENT CATEGORY and its  
328 nominal AC RMS line-to-neutral or DC voltage of MAINS is permissible.

329 *Conformity is checked by inspection.*

330 The nominal AC RMS line-to-neutral or DC voltage of MAINS for the MEASUREMENT CATEGORY is  
331 given in the 7<sup>th</sup> column of Table I.1 from Annex I (Line-to-neutral pertinent to MAINS system type  
332 and nominal voltage) for MAINS supply systems up to 1 000 V.

333 The phase-to-phase voltage on these MAINS supply systems can be higher than the nominal AC  
334 RMS line-to-neutral or DC voltage of MAINS for the MEASUREMENT CATEGORY.

335 EXAMPLE According to Annex I, the nominal voltages of a three-phase four-wire systems with earthed neutral in  
336 TT system can be 277 V (L-N)/480 V (L-L) while the line-to-neutral pertinent to MAINS system type (the nominal  
337 voltage nominal AC RMS line-to-neutral or DC voltage of MAINS) is 300 V.

338 The RATED voltage of the TERMINALS of a MEASURING CIRCUIT intended for MAINS voltage  
339 measurements shall be equal to or higher than their nominal AC RMS line-to-neutral or DC  
340 voltage of the MAINS RATED for the MEASUREMENT CATEGORY.

341 *Conformity is checked by inspection.*