

---

**Instrumentni transformatorji - 22. del: Instrumentni transformatorji v sklopu z drugimi napravami z  $U_m = 36$  kV - Zahteve in preskusi**

Instrument transformers - Part 22: Instrument transformers integrated with other devices with  $U_m = 36$  kV - Requirements and tests

Transformateurs de mesure - Partie 22: Transformateurs de mesure intégrés à d'autres appareils avec  $U_m = 36$  kV - Exigences et essais

**Ta slovenski standard je istoveten z: prEN IEC 61869-22:2025**

oSIST prEN IEC 61869-22:2025

<https://standards.iteh.ai/catalog/standards/sist/e8ee06c2-6bf9-4e3b-ab61-b2b4582b718e/osist-pren-iec-61869-22-2025>

**ICS:**

17.220.20	Merjenje električnih in magnetnih veličin	Measurement of electrical and magnetic quantities
-----------	---	---

**oSIST prEN IEC 61869-22:2025****en**





# 38/820/CDV

## COMMITTEE DRAFT FOR VOTE (CDV)

PROJECT NUMBER:

**IEC 61869-22 ED1**

DATE OF CIRCULATION:

**2025-06-13**

CLOSING DATE FOR VOTING:

**2025-09-05**

SUPERSEDES DOCUMENTS:

**38/802/CD, 38/806A/CC**

IEC TC 38 : INSTRUMENT TRANSFORMERS	
SECRETARIAT: Italy	SECRETARY: Mr Filippo Frugoni
OF INTEREST TO THE FOLLOWING COMMITTEES: TC 17, TC 20, TC 32, SC 32A, TC 33, TC 36, SC 36A	HORIZONTAL FUNCTION(S):
ASPECTS CONCERNED: Electricity transmission and distribution	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING <b>Attention IEC-CENELEC parallel voting</b> The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) is submitted for parallel voting. The CENELEC members are invited to vote through the CENELEC online voting system.	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING

oSIST prEN IEC 61869-22:2025

<https://standards.iteh.ai/catalog/standards/sist/e8ee06e2-6bf9-4e3b-ab61-b2b4582b718e/osist-pren-iec-61869-22-2025>

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Recipients of this document are invited to submit, with their comments, notification of any relevant "In Some Countries" clauses to be included should this proposal proceed. Recipients are reminded that the CDV stage is the final stage for submitting ISC clauses. (SEE [AC/22/2007](#) OR [NEW GUIDANCE DOC](#)).

TITLE:

**Part 22: Instrument transformers integrated with other devices with  $U_m \leq 36$  kV - Requirements and tests**

PROPOSED STABILITY DATE: 2031

NOTE FROM TC/SC OFFICERS:

**Copyright © 2025 International Electrotechnical Commission, IEC.** All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

# CONTENTS

1	FOREWORD.....	4
2	INTRODUCTION.....	6
3	1 Scope.....	7
4	2 Normative references .....	7
5	2.1 Instrument transformers .....	7
6	2.2 Fuses .....	8
7	2.3 Insulators and bushings .....	8
8	2.4 Cables .....	8
9	3 Terms and definitions .....	8
10	4 Normal and special service conditions .....	9
11	5 Ratings.....	9
12	6 Design and construction .....	9
13	6.1 General.....	9
14	6.2 Instrument transformers integrated in air insulated cable terminations .....	9
15	6.3 Instrument transformers integrated in screened separable connectors for cables.....	10
16	6.4 Instrument transformers integrated in bushings.....	10
17	6.5 Instrument transformers integrated in indoor air-post insulators .....	10
18	6.6 Instrument transformers integrated in outdoor air-post insulators .....	11
19	6.7 Voltage transformers with integrated fuses .....	11
20	6.8 Voltage transformers with plug-in bushing primary terminals.....	12
21	7 Tests .....	13
22	7.1 General.....	13
23	7.2 ITs integrated in terminations for extruded insulation cables .....	13
24	7.2.1 General .....	13
25	7.2.2 Tests for ITs integrated in terminations for extruded insulation cables .....	13
26	7.2.3 Routine tests for ITs integrated in terminations for extruded insulation cables.....	15
27	7.3 ITs integrated in screened separable connectors for cables .....	16
28	7.3.1 General .....	16
29	7.3.2 Tests for ITs integrated in screened separable connectors for cables .....	16
30	7.3.3 Routine tests for ITs integrated in screened separable connectors for cables.....	17
31	7.4 ITs integrated in bushings.....	18
32	7.4.1 Tests for ITs integrated in bushings .....	18
33	7.5 ITs integrated in indoor air-post insulators .....	19
34	7.6 ITs integrated in outdoor air-post insulators .....	21
35	7.7 Voltage Transformers with integrated fuses .....	22
36	7.8 Voltage Transformers with plug-in bushing primary terminals.....	22
37	Annex A (informative) List of additional tests to be in compliance with HD 629.1.S3 .....	24
38	A.1 ITs embedded in terminations for extruded insulation cables.....	24
39	A.2 ITs embedded in screened separable connectors for cables .....	24
40	Bibliography.....	25